

Voltage Profile Improvement of KR Power Network Using Reactive Power Control

Towana S. Husein
Substation Dep.
G. D. of Transmission, Ministry of Electricity
Erbil, Iraq
towana.salah@gmail.com

Ameen A. AbdulFatah
Electrical Engineering Dep.
College of Engineering, Salahaddin University
Erbil, Iraq

Abstract — The growth of demand and so the generation causes the Kurdistan Regional (KR) network to be heavily loaded which lead to high drop voltages across the lines and cause the bus voltage at the some nodes to be under the permissible level. In this study, PSSTME software has been used to simulate and analyse the KR network. The worst voltage profile has been used for year 2013. The load flow analysis results appeared that the voltage at most nodes are below the permissible value (for example the lowest voltage is at Soran bus 0.8629 pu). To improve the voltage profile SVC facilities are proposed. To apply SVC device; weak buses are found and the SVC device is placed at this bus. Results show great improvement in the voltage profile (for example the lowest voltage after application of SVC is 0.9423 pu), reduce losses and also increase the lines' capacity.

Keywords-component; Volatge profile, SVC, weak bus.

I. INTRODUCTION

With growing up of a power system and increasing demand, voltage sag will decrease and become serious problem. When load is increased, more reactive power is required and if there is shortage of reactive power in the network, it is expected voltage sag will be decrease. To improve voltage level injection of reactive power in network is required; FACTS controller could be a good solution to support network with required reactive power [1, 2].

Shortage of reactive power is due to consumer's low power factor, losses of reactive power in transmission system or insufficient generation of reactive power from power source itself.

The rapid developments of power electronics give opportunities to produce new power system devices that can be perform better with higher efficiency than existing system. Flexible AC Transmission System (FACTS) technology have been proposed and implemented. FACTS devices can be effectively used to control power flow (active power and reactive power), voltage regulation and improvement of transient stability in the power system [3, 4]. Both Static Var Compensator (SVC) and Static Synchronous Compensator (STATCOM) are two types of FACTS devices which are mainly used to control reactive power and voltage stability [5, 6]. In this paper, SVC has been used to improve voltage profiles in KR power network (Figure 1).




Figure 1 KR Power Network

II. SIMULATION OF KR NETWORK

Daily generation data for all power plants have been collected for the year 2013 because these data are useful to dedicate (date) the peak load for each season. Daily load curve have been plotted for each peak loads to know exact time that maximum load happened and used as input data to simulator.

Siemens Power System Simulator (PSSTME Version 31) had been used as main program. Five scenarios have been build up in simulator, after running of simulator it shows worst scenario is at summer season and there are 31.6% of substations their voltage drop under allowable rang (according to the Iraqi Grid Code for 132kV is $\pm 10\%$) [7]. List of buses that have voltage problems are shown in Figure 2 and more details are shown in Appendix I.

```

PTI INTERACTIVE POWER SYSTEM SIMULATOR--PSS(tm)E   WED, AUG 20 2014  12:29
KRG - NETWORK
TOWANA S.

BUSES WITH VOLTAGE GREATER THAN 1.1000:

BUS# X-- NAME --X BASKV AREA  V(PU)  V(KV)      BUS# X-- NAME --X BASKV AREA  V(PU)  V(KV)
* NONE *

BUSES WITH VOLTAGE LESS THAN 0.9000:

BUS# X-- NAME --X BASKV AREA  V(PU)  V(KV)      BUS# X-- NAME --X BASKV AREA  V(PU)  V(KV)
10000 AORA      132.00  1 0.9000 118.80  10500 FALSAN MOB 132.00  1 0.8969 118.39
10501 AQR JOIN  132.00  1 0.8999 118.79  13040 EERB1      132.00  2 0.8992 118.69
13060 EERB1     132.00  2 0.8982 118.57  13070 PRZEN     132.00  2 0.8966 118.35
13081 EERB2     132.00  2 0.8965 118.34  13090 NEWERB    132.00  2 0.8970 118.41
13100 SIDN      132.00  2 0.8815 116.36  13110 SORAN2    132.00  2 0.8629 113.91
13504 QALAT MOB 132.00  2 0.8999 118.66  13510 HAMREN MOB 132.00  2 0.8995 118.73
13511 KAREZAN MOB 132.00  2 0.8996 118.75  13520 SAFEN MOB  132.00  2 0.8962 118.29
13521 BAKUR MOB  132.00  2 0.8967 118.36  13522 HIWA MOB   132.00  2 0.8965 118.34
13523 MALAMEER MOB132.00  2 0.8894 117.40  13524 KASNAZAN MOB132.00  2 0.8977 118.50
13525 SORAN JOIN1 132.00  2 0.8775 115.83  13526 SORAN JOIN2 132.00  2 0.8784 115.95
13527 RAWANDUZ MOB132.00  2 0.8658 114.29  13528 KHALIFAN MOB132.00  2 0.8715 115.04
13529 SPTLK MOB  132.00  2 0.8742 115.40  13530 SHAQLAWA MOB132.00  2 0.8812 116.32
13531 HARIH MOB   132.00  2 0.8786 115.97  13532 AGRA JOIN1  132.00  2 0.8808 116.27
13533 AGRA JOIN2  132.00  2 0.8818 116.40  14001 CEREK      132.00  3 0.8997 118.76
14020 QALADEA    132.00  3 0.8887 117.30  15300 DIRIS     132.00  4 0.8814 116.34
    
```

Figure 2 List of buses their voltages exceeds ±10%

III. WEAK BUS

The weakest bus is the one that is nearest to experience voltage collapse in the system [8]. In this paper some technics have are used to find the week bus, which are:

A. PV and QV Curves

The PV curve or "nose curve" and QV curve are load flow based analyses used to assess voltage variation when active power and reactive power of load change. PV is one of the method that widely used for stability analysis; it shows how bus voltage affected by variation of active power. By increasing the load at chosen bus bar in the system (other loads are fixed) and getting responses form sources until the system reaches the limit and get crashes. This procedure has to follow for each bus bar in the system that required to be investigated. If the load continuously increases more than maximum active power generation, voltage collapse will happen and the system get blackout. QV analysis shows the sensitivity and variation of bus voltages with respect to reactive power injections or absorptions by loads. Actually, it is a plotting of (V & Q) but it is still by tradition called QV curve. By same procedure QV curve can be plotted and if generation reactive powers exceed limit value (bottom of curve) voltage collapse will happened [8, 9, 10].

B. V/V₀ Index

The ratio V/V₀ at each bus shows the voltage stability map of the system. V is the bus voltage at certain load obtained from load flow study. Voltages V₀ are obtained by solving load flow of the system at an identical state but with all other loads set to zero. This index allows immediate detection of weakest bus and corrective action can be taken to prevent the voltage instability [8, 9].

IV. SEARCHING FOR WEAK BUS

To find the weakest bus in network same simulator has been used as following:

- i. PV Curve: the PSSTME software has capability to show PV analysis for certain buses (maximum 8) at same plot. To find weakest bus, some busses have been selected according to their lowest voltage values as shown in the Figure 3. From the curve it is noticed

that voltage collapse will happened at maximum loading of ($\lambda = 231/100 \rightarrow 2.31$ Pu), and it is indicated that Soran2 bus (13110) is the weakest bus in system.




Figure 3 PV curve seeking for weak bus

- ii. QV Curve: the PSSTME will draw the relation between Q and V only for a single bus, for that reason this QV analysis have been done for the same 8 worst buses in PV curve analysis and plotted in excel file as shown in Figure 4. It can be illustrated that Soran2 bus (13110) has lowest minimal margin of reactive power respectively; this indicate most critical bus in the system where could be best location to install SVC devices.




Figure 4 QV curve seeking for weak bus

- iii. V/V₀ Index: to get this index several times of load flow have been run for loading factor ($\lambda=0.5$ & 1.0) and results are shown in Figure 5. It is noticed that at load factor ($\lambda=0.5$) the results are approximately close to each other but after increasing loading factor up to ($\lambda=1.0$) it can be demonstrated that "Soran2 bus" has the lowest value (0.858).




Figure 5 V/Vo index to find for weak bus

V. RESULTS

PV curve, QV curve and V/Vo index shows “Soran2 bus” is the weakest bus in the network that needs reactive power support to improve its voltage level. SVC has been added at the weak bus "Soran2 bus". The problem of voltage in entire of the network has been solved and their operating voltages are in limit range when SVC device produced 128.5 MVAR. Figure 6 shows a report that the entire network voltage problems have been solved.

```

PTI INTERACTIVE POWER SYSTEM SIMULATOR--PSS(tm)E  WED, AUG 20 2014 12:34
KRG - NETWORK
TOWANA S.
BUSES WITH VOLTAGE GREATER THAN 1.1000:
BUS# X-- NAME --X BASKV AREA  V(PU)  V(KV)  BUS# X-- NAME --X BASKV AREA  V(PU)  V(KV)
      * NONE *
BUSES WITH VOLTAGE LESS THAN 0.9000:
BUS# X-- NAME --X BASKV AREA  V(PU)  V(KV)  BUS# X-- NAME --X BASKV AREA  V(PU)  V(KV)
      * NONE *
    
```

Figure 6 List of buses after compensation

Results show that:

- Voltage profile: it have been taken before and after adding SVC at each bus in the network. Figure 7 shows the voltage profile before adding SVC. It can be observed how the network is suffering from low voltage when there are many of buses are under minimum allowable voltage (0.9) pu. Figure 8 shows the voltage profile after adding SVC at Soran bus. It can be observed all buses are between minimum and maximum allowable voltage range.




Figure 7 Voltage profile before adding SVC




Figure 8 Voltage profile after adding SVC

- Maximum Loading Factor (λ); the maximum loading was equal to 2.31p.u but after adding SVC this value have been increased to 4.0p.u.
- Active and reactive power losses: Figure 9 shows the results Government transmission losses before adding SVC to the network, the total losses in the network (GOV) was 65.7 MW and 332.1 MVAR. But after adding the total losses in the network (GOV) is 57.3 MW and 291.7 MVAR as shown in Figure 10.

PTI INTERACTIVE POWER SYSTEM SIMULATOR--PSS(tm)E MON, SEP 01 2014 23:29						
KRG - NETWORK						
TOWANA S.						
						OWNER TOTALS
						IN MW/MVAR
X- OWNER	--X GENERATION	TO LOAD	TO BUS SHUNT	TO LINE SHUNT	FROM CHARGING	LOSSES
1	0.0	2837.1	0.0	0.0	0.0	65.7
GOV	0.0	1363.2	-277.0	0.0	232.4	332.1
2	2210.9	0.0	0.0	0.0	0.0	0.0
MASS	1158.1	0.0	0.0	0.0	0.0	348.8
3	138.1	0.0	0.0	0.0	0.0	0.0
BAADRA	66.8	0.0	0.0	0.0	0.0	0.0
4	69.8	0.0	0.0	0.0	0.0	0.0
29MW CO	36.0	0.0	0.0	0.0	0.0	0.0
11	484.0	0.0	0.0	0.0	0.0	0.0
GOV HPP	340.0	0.0	0.0	0.0	0.0	66.2
TOTALS	2902.8	2837.1	-277.0	0.0	0.0	65.7
	1601.0	1363.2			232.4	747.2

Figure 9 power losses before adding SVC

PTI INTERACTIVE POWER SYSTEM SIMULATOR--PSS (tm)E							MON, SEP 01 2014 23:17
KRG - NETWORK							OWNER TOTALS
TOWANA S.							IN MW/MVAR
X- OWNER	--X GENERATION	TO LOAD	TO BUS SHUNT	TO LINE SHUNT	FROM CHARGING	LOSSES	
1	0.0	2837.1	0.0	0.0	0.0	57.3	
GOV	0.0	1363.2	-425.6	0.0	252.1	291.7	
2	2202.6	0.0	0.0	0.0	0.0	0.0	
MASS	1059.1	0.0	0.0	0.0	0.0	341.3	
3	138.1	0.0	0.0	0.0	0.0	0.0	
BAADRA	20.9	0.0	0.0	0.0	0.0	0.0	
4	69.8	0.0	0.0	0.0	0.0	0.0	
29MW CO	27.9	0.0	0.0	0.0	0.0	0.0	
11	484.0	0.0	0.0	0.0	0.0	0.0	
GOV HFP	263.3	0.0	0.0	0.0	0.0	52.7	
TOTALS	2894.4	2837.1	0.0	0.0	0.0	57.3	
	1371.2	1363.2	-425.6	0.0	252.1	686.7	

Figure 10 power losses after adding SVC

- VAR Generation: total VAR generations in power plants after adding SVC have been reduced from 1600.4 MVAR to 1371.4 MVAR.

VI. CONCLUSION

SVC device have been added to the power network and analyzed, from results that obtained it can conclude;

- Adding SVC device in network will significantly help to improve voltage profile and operate network within the allowable range.
- Improving system stability which help to reduce total blackout of network
- Active power and reactive power losses in transmission will be decrease.
- Transmitting capability of transmission lines will be increase.

- Generation power plants perform better and their capability of active generation will be increase with decreasing of reactive power generation.

REFERENCES

- [1] Vanishree J., Ramesh V., "Voltage profile improvement in power systems - A review", Advances in Electrical Engineering (ICAEE), International Conference on 2014, pp. 1-4, Jan 2014
- [2] Anitha C., Arul P., "Enhancement of voltage stability in transmission system using SSSC", Circuit Power and Computing Technologies (ICCPCT), International Confrance 2014, vol.1, pp 30-33, March 2014. I.
- [3] Lijun Cai, "Robust coordinated control of FACTS devices in large power systems", published by Logos Verlag, Berlin, ISBN: 3-8325-0570-9, 2004.
- [4] Allan Johns, Yong-Hua Song, "Flexible Ac Transmission Systems (FACTS) ", The Institution of Engineering and Technology, London, Dec. 1999
- [5] Ding Lijie, Liu Yang; Miao Yiqun, "Comparison of high capacity SVC and STATCOM in real power grid", Intelligent Computation Technology and Automation (ICICTA), International Conference, vol. 1, pp. 993 – 997, 2010
- [6] Jagadeesh K. M., Subhransu S. D., Harish K. S., Subramani C., Palanivel P., "Comparison OF Optimization Technique To Find The Optimal Location of FACTS Controllers For Transmission Line" American Journal of Applied Sciences, vol. 11, no. 2, pp. 280-290, 2014.
- [7] M. O. Electricity, Iraq Grid Code, V2.1, Baghdad: PB consultant Co., Jan 2011.
- [8] A. R. Phadke, S. K. Bansal, K. R. Niazi, "A Comparison of Voltage Stability Indices for Placing Shunt FACTS Controllers" First International Conference on Emerging Trends in Engineering & Technology ICETET 2008, pp. 939-944, July 2008.
- [9] Claudia Reis, F.P. Maciel Barbosa, "A Comparison of Voltage Stability Indices", Electrotechnical Conference, Melecon, Spain. IEEE Mediterranean, pp. 1007-1010, May 2006.
- [10] T. Sai Sudheer, J. Srinivasa Rao, J. Amarnath, "Optimal Location of the Facts Devices using the Sensitivity Approach for the Enhancement of ATC and Voltage Profile in Deregulated Power System", International Journal of Computer Applications, vol. 76, no. 10, pp. 32-38, August 2013.

Appendix I
Load Flow Analysis before Compensation (Filtered)

PTI INTERACTIVE POWER SYSTEM SIMULATOR--PSS(tm)E FRI, Mar 11 2016 22:27

KR - NETWORK / BEFORE ADDING FACTS DEVICES

BUS DATA

TOWANA S.

S H U N T S

BUS#	X--	NAME	--X	BASKV	CODE	LOADS	FIXED	SWITCHED	VOLT	ANGLE	AREA	ZONE	OWNER
10000	AQRA	132.00	1	1	1	0	0.899999	-31.5	1	10	1		
10010	BAADRA	132.00	2	0	0	0	0.99350	-14.5	1	10	1		
10020	EDHK	132.00	-2	1	1	0	1.00395	-12.9	1	10	1		
10040	WDHK	132.00	1	1	1	0	1.01009	-12.0	1	10	1		
10050	TANAHI	132.00	1	1	1	0	1.01317	-11.8	1	10	1		
10060	SUMEL1	132.00	1	1	1	0	1.02127	-10.6	1	10	1		
10061	SUMEL2	132.00	1	1	1	0	1.01625	-11.3	1	10	1		
10070	FAYDA	132.00	1	1	0	0	1.00777	-12.5	1	10	1		
10080	DHKGPS	132.00	1	0	0	0	1.02380	-10.3	1	10	2		
10082	GDHK1	15.000	2	0	0	0	0.96772	27.3	1	10	2		
10083	GDHK2	15.000	2	0	0	0	0.96756	27.4	1	10	2		
10084	GDHK3	15.000	2	0	0	0	0.96756	27.4	1	10	2		
10085	GDHK4	15.000	2	0	0	0	0.96739	27.4	1	10	2		
10086	GDHK5	15.000	2	0	0	0	1.05848	26.0	1	10	2		
10087	GDHK6	15.000	2	0	0	0	1.05848	26.0	1	10	2		
10088	GDHK7	15.000	2	0	0	0	1.05848	26.0	1	10	2		
10089	GDHK8	15.000	4	0	0	0	1.00000	0.0	1	10	2		
10090	SRSNK	132.00	1	1	1	0	1.01279	-11.8	1	10	1		
10100	ZAKHO	132.00	1	1	1	0	1.00262	-12.5	1	10	1		
10500	PALSAN MOB	132.00	1	1	0	0	0.89692	-34.6	1	10	1		
10501	AQR JOIN	132.00	1	0	0	0	0.89991	-34.1	1	10	1		
10502	MAHAD MOB	132.00	1	1	0	0	0.95127	-20.2	1	10	1		
10503	NAHADRA MOB	132.00	1	1	0	0	0.97821	-16.4	1	10	1		
10504	ASHQAN MOB	132.00	1	1	0	0	0.92115	-25.7	1	10	1		
10510	SRSNKJOIN1	132.00	1	0	0	0	1.02033	-11.1	1	10	1		
10511	SRSNKJOIN2	132.00	1	0	0	0	1.00798	-12.6	1	10	1		
10512	ALQOSH MOB	132.00	1	1	0	0	0.99828	-13.8	1	10	1		
10513	SHARYA MOB	132.00	1	1	0	0	1.00664	-12.6	1	10	1		
13000	ERBGPS	132.00	1	0	0	0	0.92550	-34.9	2	13	2		
13002	GERB1	15.000	3	0	0	0	0.92550	0.0	2	13	2		
13003	GERB2	15.000	2	0	0	0	0.96489	3.3	2	13	2		
13004	GERB3	15.000	2	0	0	0	0.96486	3.3	2	13	2		
13005	GERB4	15.000	2	0	0	0	0.96446	3.5	2	13	2		
13006	GERB5	15.000	2	0	0	0	0.96547	3.0	2	13	2		
13007	GERB6	15.000	2	0	0	0	0.96519	3.2	2	13	2		
13008	GERB7	15.000	2	0	0	0	0.96563	2.9	2	13	2		
13009	GERB8	15.000	2	0	0	0	0.96429	3.6	2	13	2		
13020	WERB	132.00	1	1	1	0	0.90669	-36.6	2	13	1		
13030	SERB	132.00	1	1	1	0	0.90319	-37.2	2	13	1		
13037	POLTIKS	132.00	4	1	0	0	1.00000	0.0	2	13	1		
13040	EERB1	132.00	1	2	2	0	0.89917	-37.9	2	13	1		
13041	EERB2	132.00	4	0	0	0	1.00000	0.0	2	13	1		
13050	AZADI1	132.00	1	3	1	0	0.90105	-37.4	2	13	1		
13051	AZADI2	132.00	4	0	1	0	1.00000	0.0	2	13	1		
13060	ERBP1	132.00	1	1	1	0	0.89822	-37.6	2	13	1		

13070	PRZEN	132.00	1	1	1	0	0.89660	-38.0	2	13	1
13080	ERBN1	132.00	4	0	0	0	1.00000	0.0	2	13	1
13081	ERBN2	132.00	-2	1	1	0	0.89651	-38.2	2	13	1
13090	NEWERB	132.00	1	1	1	0	0.89703	-38.1	2	13	1
13100	SLDN	132.00	2	1	0	0	0.88151	-38.3	2	13	1
13110	SORAN2	132.00	2	2	2	0	0.86294	-40.2	2	13	1
13111	SORAN1	132.00	4	0	0	0	1.00000	0.0	2	13	1
13130	KOYA	132.00	1	1	0	0	0.94420	-37.1	2	13	1
13500	LAJAN MOB	132.00	1	1	0	0	0.92327	-35.1	2	13	1
13501	SHAMAMK MOB	132.00	1	1	0	0	0.91796	-35.7	2	13	1
13502	BAHRKA MOB	132.00	1	1	0	0	0.92222	-35.3	2	13	1
13503	MURTKA MOB	132.00	1	1	0	0	0.91371	-36.1	2	13	1
13504	QALAT MOB	132.00	1	1	0	0	0.89891	-37.8	2	13	1
13505	TURAQ MOB	132.00	1	1	0	0	0.90378	-37.0	2	13	1
13506	KHABAT JOIN1	132.00	1	0	0	0	0.91020	-36.6	2	13	1
13507	KHABAT JOIN2	132.00	1	0	0	0	0.91019	-36.6	2	13	1
13508	ERBP JOIN1	132.00	1	0	0	0	0.90821	-36.7	2	13	1
13509	ERBP JOIN2	132.00	1	0	0	0	0.90769	-36.7	2	13	1
13510	HAMREN MOB	132.00	1	1	0	0	0.89950	-37.8	2	13	1
13511	KAREZAN MOB	132.00	1	1	0	0	0.89960	-37.7	2	13	1
13520	SAFEN MOB	132.00	1	1	0	0	0.89616	-38.1	2	13	1
13521	BAKUR MOB	132.00	1	1	0	0	0.89669	-38.2	2	13	1
13522	HIWA MOB	132.00	1	1	0	0	0.89652	-38.2	2	13	1
13523	MALAOMER MOB	132.00	1	1	0	0	0.88940	-38.3	2	13	1
13524	KASNAZAN MOB	132.00	1	1	0	0	0.89770	-38.0	2	13	1
13525	SORAN JOIN1	132.00	1	0	0	0	0.87748	-38.6	2	13	1
13526	SORAN JOIN2	132.00	1	0	0	0	0.87844	-38.6	2	13	1
13527	RAWANDUZ MOB	132.00	1	1	0	0	0.86580	-39.9	2	13	1
13528	KHALIFAN MOB	132.00	1	1	0	0	0.87149	-39.3	2	13	1
13529	SPILK MOB	132.00	1	1	0	0	0.87421	-39.0	2	13	1
13530	SHAQLAWA MOB	132.00	1	1	0	0	0.88118	-38.1	2	13	1
13531	HARIR MOB	132.00	1	1	0	0	0.87857	-38.4	2	13	1
13532	AQRA JOIN1	132.00	1	0	0	0	0.88084	-38.0	2	13	1
13533	AQRA JOIN2	132.00	1	0	0	0	0.88182	-37.9	2	13	1
13534	KANI MOB	132.00	1	1	0	0	0.90284	-35.1	2	13	1
13535	KAWRGOSK MOB	132.00	1	1	0	0	0.90047	-34.9	2	13	1
13537	CHALOK MOB	132.00	1	1	0	0	0.90203	-34.8	2	13	1
13538	KOYA MOB	132.00	1	1	0	0	0.93833	-37.3	2	13	1
13539	TAQTAQ MOB	132.00	1	1	0	0	0.94127	-37.2	2	13	1
14001	CHRK	132.00	1	1	1	0	0.89968	-38.7	3	14	1
14010	DOKAN	132.00	1	1	0	0	0.98132	-35.5	3	14	11
14012	HDK01	13.800	-2	0	0	0	0.95147	-1.4	3	14	11
14013	HDK02	13.800	-2	0	0	0	0.95147	-1.4	3	14	11
14014	HDK03	13.800	-2	0	0	0	0.95147	-1.4	3	14	11
14015	HDK04	13.800	-2	0	0	0	0.95147	-1.4	3	14	11
14016	HDK05	13.800	-2	0	0	0	0.95147	-1.4	3	14	11
14020	QALADZA	132.00	1	1	1	0	0.88866	-39.3	3	14	1
14030	TSLJ	132.00	1	1	1	0	0.97763	-35.9	3	14	1
14040	CHAM GPP	132.00	1	0	0	0	1.01100	-33.4	3	14	2
14042	GCHAM1	15.000	2	0	0	0	0.98339	0.7	3	14	2
14043	GCHAM2	15.000	2	0	0	0	0.97796	4.2	3	14	2
14044	GCHAM3	15.000	2	0	0	0	0.97796	4.2	3	14	2
14045	GCHAM4	15.000	2	0	0	0	0.97781	4.3	3	14	2
14046	GCHAM5	15.000	2	0	0	0	0.97796	4.2	3	14	2
14047	GCHAM6	15.000	2	0	0	0	0.97781	4.3	3	14	2
14048	GCHAM7	15.000	2	0	0	0	0.97857	3.9	3	14	2
14049	GCHAM8	15.000	2	0	0	0	0.97842	4.0	3	14	2
14060	CHCHL	132.00	1	1	0	0	1.00330	-33.9	3	14	1
14070	SULMW	132.00	-2	1	0	0	0.99234	-35.2	3	14	1
14080	RZGARI	132.00	1	1	1	0	0.98824	-35.6	3	14	1

14100	ZARGA	132.00	1	1	0	0	0.98579	-35.8	3	14	1
14110	AZMR1	132.00	1	1	1	0	0.98447	-36.0	3	14	1
14120	SSLM	132.00	1	1	1	0	0.97718	-36.8	3	14	1
14130	DBKH	132.00	1	1	0	0	0.96860	-36.6	3	14	11
14136	HDP1	13.800	-2	0	0	0	0.92209	1.0	3	14	11
14137	HDP2	13.800	-2	0	0	0	0.92209	1.0	3	14	11
14138	HDP3	13.800	-2	0	0	0	0.92209	1.0	3	14	11
14140	KLAR	132.00	1	1	1	0	0.91397	-43.6	3	14	1
14150	SSDK	132.00	1	1	0	0	0.94719	-38.5	3	14	1
14170	KHANAQEN	132.00	1	1	0	0	0.91423	-43.8	3	14	1
14500	QARAHR MOB	132.00	1	1	0	0	0.99641	-34.4	3	14	1
14501	BAKO MOB	132.00	1	1	0	0	0.99220	-35.2	3	14	1
14502	BAZAN FAC	132.00	1	1	0	0	0.99930	-34.5	3	14	1
14503	TAKEA MOB	132.00	1	1	0	0	1.00646	-33.8	3	14	1
14504	SHRKZH	132.00	1	1	0	0	0.99001	-35.3	3	14	1
14505	IRON FAC	132.00	1	1	0	0	1.00219	-34.1	3	14	1
14506	TSLJ MOB	132.00	1	1	0	0	0.98374	-35.4	3	14	1
14507	MASCFAC1	132.00	1	1	0	0	0.98981	-35.0	3	14	1
14508	MASCFAC2	132.00	1	1	0	0	0.98981	-35.0	3	14	1
14509	KAZWA MOB	132.00	1	1	0	0	0.97938	-36.5	3	14	1
14510	KALAR MOB	132.00	1	1	0	0	0.90440	-44.5	3	14	1
14511	HAWARI MOB	132.00	1	1	0	0	0.98126	-36.0	3	14	1
14512	JOINS1	132.00	1	0	0	0	0.99513	-34.8	3	14	1
14513	JOINS2	132.00	1	0	0	0	0.99675	-34.7	3	14	1
15300	DIBIS	132.00	1	1	0	0	0.88140	-38.4	4	15	1
15310	KRK3	132.00	1	1	0	0	0.96118	-36.7	4	15	1
16001	MOSULDAM	132.00	1	1	0	0	0.99359	-14.3	5	16	1